


Outline installation & maintenance instructions – Hidden Valves



Key


Component	Qty
A Radiator	1
B Wall mounting brackets	4 as standard, 6 or 8 on larger radiators (these are attached to radiator manifold with ties for transit)
C Screws*	2 per bracket
D ½" BSP to ½" BSPT adaptor	2
E Braided hoses with ¼ turn manual ball valve incorporated	2

* Screws and wall plugs are not supplied with radiator. Screws must be selected according to wall material and construction, i.e. brickwork, plasterboard, wood panelling etc. The maximum design loading per fixing is 8kg.

Tools required

Spanner to suit adaptors and hose assemblies
 PTFE tape (high density tape is preferred)
 Tape measure
 Spirit Level
 Electric Drill
 Masonry drill bit to suit wall plug or screw size (Eskimo brackets will take screws up to 7mm in diameter)
 Screws & Wall plugs as required
 Screwdriver
 Bleed Key

Installation Instructions



1. Before starting work, ensure working area is free of obstructions and objects that could cause harm to you or the radiator. Unpack radiator carefully but **do not fully remove protective plastic film until installation is complete, if necessary unpeel film to check for transit damage then replace.** If laying the radiator onto the floor, place it with the back (aluminium heat exchanger) face to the floor, unless you can ensure that there is nothing underneath that could cause damage to the flat panel face – grit or foreign objects can scratch the flat panel through the protective film.
2. Apply sufficient PTFE tape or liquid sealant to BSPT (taper) threads to provide a leak-tight seal.
3. Screw BSPT (taper end) of adaptor into threaded pipe connections on radiators **please note, the female aluminium threads in the radiator can be damaged by cross-threading of the adaptor – ensure that thread is correctly aligned before tightening.** Do not over-tighten.
4. Measure horizontal bracket positions on back of radiator, vertical positions are shown on drawing above. Refer this to bracket mounting holes and accurately mark out hole positions on wall using a spirit level and tape measure taking particular care to ensure that the stub pipes are in the correct position relative to the front panel.
5. Drill holes *for slotted bracket hole only* in wall as required by screws and wall plugs used.
6. Attach brackets (B) to wall initially with one screw only through slotted hole ensuring the hook is at the top.
7. Check brackets for alignment using spirit level, and adjust as necessary, then drill and screw second bracket hole. **It is essential that all brackets align correctly with their corresponding mounting positions on the radiator – the radiator must not be forced onto misaligned brackets or damage may occur causing the radiator to leak.**
8. Now fit the braided hoses fitting the compression ends on the stub pipes and the threaded ends with the washers onto the 1/2" BSP adaptor now sticking out of the radiator connections. Open valves fully.
9. Hang the radiator onto the brackets ensuring all brackets are fully engaged. **Radiators are a heavy item, and many of the radiators in our range require more than 1 person to lift them safely. Never attempt to mount a radiator that you cannot comfortably lift.**
10. Plumb radiator into heating circuit in accordance with current ISO standards, paying particular attention to the flushing of the system and the dosing of the system with a corrosion inhibitor compatible with aluminium – Eskimo recommend Fernox MB-1, formulated for mixed metal systems. **Remove protective plastic film before subjecting radiator to heat.**
11. If installation problems arise, please refer to the Eskimo website for more detailed information, specifically on the correct venting and system balancing procedure. If problems persist, please contact the Eskimo technical department – the number is shown at the top of this page.
12. Brushed stainless steel can be cleaned with baby oil, mirror stainless steel with a proprietary cleaner. **Abrasive cleaners should never be used on Eskimo products.**